

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/5/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
1	1122	317 Glenwood Avenue			
2	1124	300 Glenwood Avenue			
3	1123	299 Glenwood Avenue			
4	1125	284 Glenwood Avenue			
5	1127	42 Conger Street			
6	1129	265 Glenwood Avenue			
7	1130	Henry Street at Glenwood Avenue			
8	1171	13 to 15 Henry in Front of Building No. 1			
9	1172	13 to 15 Henry in Front of Building No. 2			DEAD END

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/6/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
10	1170	Glenwood Avenue and Linden Avenue			
11	1141	69 Thomas Street			
12	1142	Thomas Street at Henry Street			
13	1143	104 Thomas Street			
14	1144	Thomas Street at Washington Street			
15	1146	153 Washington Street			
16	1148	159 Thomas Street			
17	1173	176 Thomas Street			
18	1149	191 Thomas Street			DEAD END
19	1145	156 Washington Street			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/7/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
20	1153	Washington Street at Washington Place			
21	1151	Washington Place at Windsor Place			
22	1150	16 Windsor Place			
23	1174	10 Appleton Road			DEAD END
24	1147	120 Washington Street			
25	1119	Washington Street and Lackawanna			
26	1120	71 Washington Street			
27	1121	55-57 Washington Street (Redevelopment side)			
28	1126	17 Lackawanna Place			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/8/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
29	1118	25 Farrand Street			
30	1117	29 Farrand Street			
31	1116	45 Farrand Street			DEAD END
32	1133	211 Glenwood Avenue			
33	1135	170 Glenwood Avenue			
34	1136	153 Glenwood Avenue			
35	1204	2 Evergreen Avenue			
36	1205	112 Glenwood Avenue			
37	1206	1 Llewellyn Place			
38	1208	55 Llewellyn Avenue			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/9/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
39	1209	87 Llewellyn Avenue			
40	1248	Senior Citizens Home-near Ashland Ave.			
41	1249	Senior Citizens Home-near Koehler Ave.			
42	1213	21 Coolidge Avenue			DEAD END
43	1214	88 Brighton Avenue			DEAD END
44	1203	50 Evergreen Avenue			
45	1202	90 Evergreen Avenue			
46	1137	152 Glenwood Avenue			
47	1138	Thomas Street at Maolis Avenue			
48	1162	34 Maolis Avenue			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/10/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
49	1161	Maolis Ave. @ Thomas St. & Clinton Ave.			
50	1160	9 Clinton Street			
51	1163	98 Maolis Avenue			
52	1164	114 Maolis Avenue			DEAD END
53	1201	104 Ashland Avenue			
54	1139	27 Thomas Street			
55	1134	200 Glenwood Avenue			
56	1140	Thomas Street at Second Street			
57	1169	52 Linden Avenue			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/11/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
58	1158	31 Clinton Street			
59	1156	41 Clinton Street			
60	1155	71 Clinton Street			
61	1157	87 Linden Avenue			
62	1166	180 Ashland Avenue			
63	1165	120 Linden Avenue			DEAD END
64	1154	89 Clinton Street			
65	1168	Ashland Avenue at Washington Street			
66	1167	Ashland Ave. Btwn Linden & Washington			
67	1244	2 Olive Street			
68	1246	25 Olive Street			

## CENTER INTERCONNECTION FLUSHING SEQUENCE

### 2022 PROGRAM

8/12/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
69	1247	48 Olive Street			
70	1245	11 Marginal Road South			
71	1242	52 Myrtle Street			
72	1241	110 Myrtle Street			
73	1243	13 Bland Court			DEAD END
74	1227	80 Prospect Street			
75	1228	90 Locust Avenue			
76	1229	78 Locust Avenue			
77	1230	58 Locust Avenue			
78	1233	151 Willow Street			
79	1231	89 Willow Street			



**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/13/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
80	1337	JFK Drive South at Parkway Admin. Bldg.			DEAD END
81	1234	166 Willow Street			
82	1236	33 Glenwood Avenue			
83	1235	7 Glenwood Avenue			DEAD END
84	1239	4 Prospect Street			DEAD END
85	1237	20 Prospect Street			
86	1238	7 Westcott Street			DEAD END
87	1210	122 North Fulton Street			
88	1211	98 North Fulton Street			
89	1215	36 Brighton Avenue			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/14/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
90	1212	48 Brighton Avenue			
91	1207	42 Llewellyn Avenue			
92	1217	96 Cleveland Terrace			
93	1218	68 Cleveland Terrace			
94	1219	36 Cleveland Terrace			DEAD END
95	1216	20 Brighton Avenue			
96	1221	61 Morse Avenue			
97	1220	25 Morse Avenue			DEAD END
98	1222	53 Fulton Street			
99	1226	78 Carteret Street			DEAD END

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/15/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
100	1225	51 Laurel Avenue			DEAD END
101	1223	81 Lenox Terrace			
102	1224	17 Fulton Street			
103	1106	579 Bloomfield Avenue			
104	1105	48 Washington Street			
105	1104	43 Washington Street			
106	2517	1 Washington Street			
107	2516	24 Washington Street			
108	1103	542 Bloomfield Avenue			
109	1128	3 Conger Street			
110	1102	535 Bloomfield Avenue			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/16/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
111	1101	499 Bloomfield Avenue			
112	2514	Bloomfield Municipal Building - Front			
113	2513	Fire HQ - Front - Franklin Street			
114	2512	Fire HQ - Side of Building			DEAD END
115	2511	353 Franklin Street			
116	2510	Burroughs Place - At Municipal Bldg. Parking Lot			
117	1108	580 Bloomfield Avenue			
118	1109	587 Bloomfield Avenue			
119	1110	616 Bloomfield Avenue			
120	1111	633 Bloomfield Avenue			
121	1112	658 Bloomfield Avenue			
122	1113	675 Bloomfield Avenue			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/17/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
123	2522	20 Broad Street			
124	2521	23 Broad Street			
125	2262	38 Broad Street			
126	2523	49 Broad Street			
127	2261	255 Liberty Street			
128	2101	Liberty Street at State Street			
129	2263	481 Franklin Street			
130	2520	455 Franklin Street			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/18/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
131	2518	417 Franklin Street			
132	2515	391 Franklin Street			
133	2531	1 Oakland Avenue			
134	2526	52 Oakland Avenue			
135	2524	58 Freemont Street			
136	2519	Fremont Street			
137	2530	10 Spruce Street			
138	2529	28 Spruce Street			
139	2527	Freemont Mid-block bet. Aokland & Spruce			
140	2270	65 Spruce Street			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/19/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
141	2269	82 Liberty Street			
142	2264	288 Liberty Street			
143	2265	21 Austin Place			
144	2266	211 Liberty Street			
145	2267	188 Liberty Street			
146	2268	85 Oakland Avenue			
147	2257	2 Park Place			
148	2256	11 to 23 Park Place			
149	2254	26 Park Place			
150	2253	80 Monroe Place			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/20/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
151	2252	52 Monroe Place			
152	2250	126 Spruce Street			
153	2255	49 to 53 Park Place			
154	2236	111 Beach Street			
155	2237	98 Beach Street			
156	2243	50 Beach Street			
157	2238	Elm Street and Beach Street			
158	2239	Church Street and Elm Street			
159	2242	Church Street, West End			
160	2235	135 Broad Street			
161	2247	Marginal Road at Furniture Outlet			



**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/21/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
162	2251	97 Spruce Street			
163	2249	135 Spruce Street			
164	2248	19 Beach Street			DEAD END
165	2245	148 Spruce Street			
166	2246	117 Spruce Street			
167	2259	94 Broad Street			
168	2260	95 Broad Street			
169	2258	5 Park Street			
170	2104	20 Park Street			
171	2105	52 State Street			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/22/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
172	2103	28 State Street			
173	2102	23 State Street			
174	2106	42 Park Street			
175	1114	58 Park Street			
176	1115	757 Bloomfield Avenue			
177	2115	9 Park Avenue			
178	2114	73 State Street			
179	2108	35 Park Avenue			
180	2107	23 Jersey Street			
181	2109	63 Park Avenue			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/23/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
182	2110	1 Edgewood Road			
183	2234	160 Broad Street			
184	2113	141 State Street			
185	2112	394 Belleville Avenue			
186	2111	31 Edgewood Road			
187	2233	350 Belleville Avenue			
188	2232	38 Elm Street			
189	2241	19 Church Street			
190	2274	Rosewood Terrace			DEAD END
191	2231	294 Belleville Avenue			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/24/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
192	2244	25 Oak Street			
193	2225	186 Broad Street			
194	2224	207 Broad Street			
195	2223	State Street and Broad Street			
196	2117	State Street (at the bend)			
197	2116	167 State Street			
198	2222	71 Maple Street			
199	2221	60 Maple Street			
200	2219	30 Maple Street			
201	2218	7 Maple Street			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/25/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
202	2227	253 Spruce Street			
203	2228	240 Spruce Street			
204	2229	223 Spruce Street			
205	2230	204 Spruce Street			
206	2226	43 New Street			
207	2214	251 Belleville Avenue			
208	2213	249 Belleville Avenue			DEAD END
209	2212	300 Walnut Street			
210	2211	291 Walnut Street			DEAD END
211	2210	200 Belleville Avenue			
212	2275	On Williamson near Belleville			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/26/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
213	2324	33 Clarendon Place			
214	2322	1 Forest Drive			
215	2323	39 Forest Drive			DEAD END
216	2216	Kennedy Drive			
217	2217	Kennedy Drive			
218	3201	Spring Street			
219	3202	85 Spring Street			
220	3204	Spring Street at East Almira			
221	3208	47 Division Street			
222	3207	10 Wilson Place			
223	3204	76 Spring Street at East Almira Street			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/27/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
224	3205	65 East Almira Street			
225	3206	East Almira Street			DEAD END
226	2273	Memorial Park Well House			DEAD END
227	3239	Broad Terrace			
228	3101	29 Broad Terrace			
229	3111	Broad Terrace at Cul-De-Sac			DEAD END
230	3236	Kennedy Drive and Almira Street			DEAD END
231	3237	2 Almira Street			
232	3238	36 Almira Street			
233	3240	300 Broad Street			
234	3235	329 Broad Street			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/28/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
235	3241	1 Waverly Terrace			
236	Private	Quick Check			DEAD END
237	3242	2 Pitt Street			
238	3245	91 Baldwin Street			
239	3246	424 Broad Street			
240	3401	443 Broad Street			
241	3402	1 Warren Street			
242	3404	548 Broad Street			
243	3405	543 Broad Street			
244	3406	Northwest Corner of Bay & Broad Servcie Station			
245	3308	191 Bay Avenue			



**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/29/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
246	3102	28 to 30 Benson Street			
247	3112	22 Osborne Street			
248	3103	58 Osborne Street			
249	3104	58 Waverly Terrace			
250	3105	Waverly Terrace			
251	3106	30 Waverly Terrace			
252	3108	38 Pitt Street			
253	3107	72 Pitt Street			
254	3244	1 Baldwin Street			
255	3110	41 Baldwin Street			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/30/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
256	3109	Baldwin Street			
257	3302	36 Warren Street			
258	3301	111 Essex Avenue			
259	3403	2 Comely Place			
260	3304	32 Comely Place			
261	3303	52 Comely Place			
262	3305	28 Vernon Terrace			
263	3306	153 Essex Avenue			
264	3307	Essex Avenue			
265	3210	39 Spring Street			
266	3211	24 Cottage Place			DEAD END

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**8/31/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
267	3223	178 Baldwin Street			
268	3222	55 North Spring Street			
269	3526	North Spring Street at Gillespie Road			
270	3524	121 North Spring Street			
271	3525	2 Gillespie Road			
272	3523	145 North Spring Street			
273	3224	79 James Street			
274	3227	13 East Passaic Avenue			
275	3243	1 James Street			
276	3226	11 Rose Place (opposite)			DEAD END

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/1/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
277	3225	12 Lois Place			DEAD END
278	3213	105 James Street			
279	3215	129 James Street			
280	3214	15 Marion Place			DEAD END
281	3212	14 Evelyn Place (opposite)			DEAD END
282	3230	166 Baldwin Street			
283	3229	130 Baldwin Street			
284	3228	110 Baldwin Street			DEAD END
285	3223	176 Baldwin street at N. Spring Street			
286	3220	198 Baldwin Street			
287	3218	14 Ridge Avenue			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/2/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
288	3217	20 Summit Avenue			
289	3216	14 Summit Avenue			
290	3247	Baldwin Street - dead-end			DEAD END
291	3233	24 Beekman Street			
292	3231	59 East Passaic Avenue			
293	3232	91 East Passaic Avenue			
294	3234	20 Marcy Street			
295	3221	59 Marcy Street			
296	3219	20 Irving Terrace			
297	3521	76 Curtis Street			
298	3520	42 Irving Terrace			
299	3511	66 Ridge Avenue			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/3/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
300	3510	62 Summit Avenue			
301	3509	Gillespie Road			DEAD END
302	3522	96 Curtis Street			
303	3518	18 Valentine Road			
304	3519	80 Irving Terrace			
305	3512	114 Ridge Avenue			
306	3513	134 Ridge Avenue			
307	3508	112 Summit Avenue			
308	3507	13 Summit Avenue			
309	3517	109 Hoover Avenue			
310	3505	143 Hoover Avenue			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/4/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
311	3514	186 Ridge Avenue			
312	3506	Hoover Avenue			
313	3534	Hoover Avenue and Shelter Place			
314	3503	71 Hoover Avenue			
315	3502	41 Hoover Avenue			
316	3501	5 Hoover Avenue			DEAD END
317	3537	Jamie Court			DEAD END
318	3536	Jamie Court			DEAD END
319	3535	Bukowski Place			DEAD END

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/5/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
320	3504	Cook Road at Town Line			DEAD END
321	3515	22 Plymouth Court			DEAD END
322	3516	Pilgrim Court			DEAD END
323	3416	268 Hoover Avenue			
324	3528	151 East Passaic Avenue			
325	3527	125 East Passaic Avenue			
326	3529	East Passaic Avenue (Rear of Station 3)			
327	3538	Seeley Court			
328	3539	Fire Station 3 (Front)			
329	3530	189 East Passaic Avenue			



**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/6/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
330	3531	215 East Passaic Avenue			
331	3532	241 East Passaic Avenue			DEAD END
332	3533	Andrew Court			DEAD END
333	Private	Whitestone Gardens			
334	Private	Whitestone Gardens			
335	Private	Whitestone Gardens			
336	Private	Whitestone Gardens			
337	3419	1 Clark Avenue			
338	3420	31 Clark Avenue			
339	3421	55 Clark Avenue			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/7/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
340	3424	85 Clark Avenue			
341	3423	20 Clark Place			DEAD END
342	3422	71 Augustus Street			DEAD END
343	3430	55 Bay Avenue			
344	3431	39 Mill Street			
345	3432	58 Mill Street			
346	3433	77 Mill Street			
347	3425	1 Lakewood Terrace			
348	3426	27 Lakewood Terrace			
349	3428	53 Lakewood Terrace			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/8/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
350	3429	89 Lakewood Terrace			DEAD END
351	3427	20 Brook Place			
352	3418	61 Morris Place			
353	3417	21 Morris Place			
354	3413	400 Hoover Avenue			
355	3414	350 Hoover Avenue			
356	3415	324 Hoover Avenue			
357	3435	10 Chapman Street			
358	3434	Bay & Broughton - northeast corner - church			
359	3441	8 Chapel Street			
360	3442	Mt. Vernon Avenue			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/9/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
361	3445	Hoover Avenue at Chapel Street			
362	3438	2 Pulaski Street			
363	3436	24 Chapel Street			
364	3437	75 Broughton Avenue			
365	4312	109 Broughton Avenue			
366	4316	135 Broughton Avenue			
367	4320	151 Broughton Avenue			
368	4324	1 Barbara Street			
369	4328	189 Broughton Avenue			
370	4332	205 Broughton Avenue			
371	4601	242 Broughton Avenue			

## CENTER INTERCONNECTION FLUSHING SEQUENCE

### 2022 PROGRAM

9/10/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
372	3440	24 Howard Street			
373	3439	32 Pulaski Street			
374	3443	50 Howard Street			
375	4313	34 Martin Street			
376	4314	62 Martin Street			
377	4315	86 Martin Street			DEAD END
378	4305	125 Birch Street			
379	4303	102 Mill Street			
380	4304	151 Birch Street			
381	4301	218 Lakewood Drive			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/11/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
382	4302	Lakewood Drive at Cul-De-Sac			DEAD END
383	4317	32 Elston Street			
384	4318	60 Elston Street			
385	4319	8 Elston Street			DEAD END
386	4321	58 Birch Street			
387	4322	32 Birch Street			
388	4323	2 Birch Street			DEAD END
389	4325	31 Barbara Street			
390	4326	61 Barbara Street			
391	4327	85 Barbara Street			DEAD END

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/12/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
392	4306	13 Union Place			
393	4307	39 Union Place			DEAD END
394	4329	31 Fritz Street			
395	4331	53 Fritz Street			DEAD END
396	4308	32 Hudson Place			
397	4309	54 Hudson Place			DEAD END
398	4333	20 Ketner Street			
399	4334	70 Ketner Street			DEAD END
400	4310	31 Norwood Place			
401	4311	45 Norwood Place			DEAD END
402	4335	Tomar Court (near Broughton)			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/13/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
403	4336	14 Tomar Court			
404	4337	26 Tomar Court			
405	4338	41 Tomar Court			DEAD END
406	4614	2 Main Terrace			
407	4615	34 Main Terrace			
408	4616	66 Main Terrace			DEAD END
409	4602	23 Walter Street			
410	4603	45 Walter Street			DEAD END
411	4604	259 Broughton Avenue			
412	4605	3 Rector Place			
413	4608	298 Broughton Avenue			



## CENTER INTERCONNECTION FLUSHING SEQUENCE

### 2022 PROGRAM

9/14/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
414	4611	336 Broughton Avenue			
415	4628	355 Broughton Avenue			
416	4703	Dewey Street			
417	4704	376 Broughton Avenue			
418	4705	385 Broughton Avenue			
419	4708	412 Broughton Avenue			
420	4711	435 Broughton Avenue			
421	4712	480 Broughton Avenue			
422	4724	485 Broughton Avenue			
423	4723	500 Broughton Avenue			
424	4728	528 Broughton Avenue			

## CENTER INTERCONNECTION FLUSHING SEQUENCE

### 2022 PROGRAM

9/15/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
425	4731	561 Broughton Avenue			
426	4735	590 Broughton Avenue			
427	4736	591 Broughton Avenue			
428	4737	Watchung Avenue at Parkway Exit			
429	4624	2 Corsi Road			
430	4623	16 Corsi Road			
431	4617	11 Sandra Lane			
432	4622	28 Corsi Road			
433	4621	53 Corsi Road			
434	4618	26 Daka Court			
435	4620	61 Corsi Road			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/16/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
436	4619	55 Daka Court			DEAD END
437	4625	2 Stone Street			
438	4626	28 Stone Street			DEAD END
439	4609	25 Fitzherbert Street			
440	4606	21 Rector Place			
441	4607	48 Rector Place			
442	4610	53 Fitzherbert Street			DEAD END
443	4627	33 Civic Place			DEAD END
444	4612	23 Ackerman Street			
445	4613	51 Ackerman Street			DEAD END
446	4629	36 Sampson Street			DEAD END
447	4715	45 Dewey Street			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/17/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
448	4716	31 Dewey Street			DEAD END
449	4706	103 Hobson Street			
450	4702	103 Dewey Street			
451	4701	131 Dewey Street			DEAD END
452	4710	16 Douglas Street			DEAD END
453	4709	139 Bessida Street			DEAD END
454	4721	107 Bessida Court			
455	4722	American Way and Bessida Street			
456	4720	Gracel Street (Dead-end)			
457	4719	20 Gracel Street			
458	4717	4 Hobson Street			

**CENTER INTERCONNECTION FLUSHING SEQUENCE  
2022 PROGRAM  
9/18/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
459	4718	Hobson Street (Dead-end)			
460	4713	1 Scott Road			
461	4714	27 Scott Road			DEAD END
462	4726	1 Palmer Street			
463	4727	31 Palmer Street			
464	4725	82 Pilch Street			
465	4732	23 Oaktree Lane			
466	4733	15 Oaktree Lane			
467	4734	8 Oaktree Lane			
468	4730	35 Pierson Street			
469	4729	5 Pierson Street			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/19/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
470	3407	577 Broad Street			
471	3408	606-612 Broad Street			
472	3409	653-661 Broad Street			
473	3410	660-666 Broad Street			
474	3412	711 Broad Street			
475	3411	712-714 Broad Street			
476	4202	755 Broad Street			
477	4203	794 Broad Street			
478	4204	797 Broad Street			
479	4205	834 Broad Street			
480	4206	839 Broad Street			

**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/20/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
361	3445	Hoover Avenue at Chapel Street			
481	4208	873 Broad Street			
482	4207	2 Sunset Avenue			
483	4111	28 Sunset Avenue			
484	4110	494 Essex Avenue			
485	4109	470 Essex Avenue			
486	4108	447 Essex Avenue			
487	4101	387 Essex Avenue			
488	3312	367 Essex Avenue			
489	3311	309 Essex Avenue			
490	3310	273 Essex Avenue			
491	3309	245 Essex Avenue			

## CENTER INTERCONNECTION FLUSHING SEQUENCE

### 2022 PROGRAM

9/21/2022

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
492	3313	1 Stonehouse Road			
493	3314	31 Stonehouse Road			
494	3315	67 Stonehouse Road			
495	3316	93 Stonehouse Road			
496	4107	219 Stonehouse Road			
497	4106	203 Stonehouse Road			
498	4105	173 Stonehouse Road			



**CENTER INTERCONNECTION FLUSHING SEQUENCE**  
**2022 PROGRAM**  
**9/22/2022**

THESE HYDRANTS ARE TO BE FLUSHED FIRST. THESE HYDRANTS SHALL BE RUN FULLY OPENED FOR A MINIMUM OF **TWENTY MINUTES** EACH, EVEN IF THE WATER IS RUNNING CLEAR. IF AT ANY POINT DURING THE FLUSHING, EVEN WITHIN THE LAST MINUTE OF THE TWENTY MINUTES, IF THE WATER BEGINS TO CHANGE OR BECOMES BROWN THE HYDRANT SHOULD REMAIN OPEN UNTIL THE WATER RUNS CLEAR AGAIN - EVEN IF THE FLUSHING EXCEEDS THE MINIMUM TWENTY MINUTE RUN TIME.

At the completion of hydrant maintenance, a work order will also be completed in the Hydrant Module of Emergency Reporting indicating a completed inspection and/or making a repair request. Take and attach pictures to the Repair Work Order to illustrate the problem or show insufficient water flow as needed. Before creating a new Repair Work Order, ensure that it is not already entered into the Emergency Reporting System.

\*If NO REPAIR is needed please ensure the work order is closed by clicking Completed.

Sequence	HYD. NO.	STREET ADDRESS	DATE FLUSHED	INITIAL	COMMENTS
499	4103	135 Stonehouse Road			
500	4104	24 Glenridge Parkway			
501	4102	119 Stonehouse Road			
502	4201	4 Glenridge Parkway			
503	Private	Lion Gate Drive			
504	Private	Lion Gate Drive			